

Approval Number 250255032  
Test Report: RG0246/C



Water Regulations Approval Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

25<sup>th</sup> February 2025

YILDIZ POLIETILEN IMALAT ITH. IHR.SAN.TIC.LTD.STI.  
KIRIKKALE OSB HACIBALI KOYU KIZILIRMAK CAD.4.SOK,  
NO:1 YAHSIHAN KIRIKKALE,  
TURKEY

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)**  
**MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**POLYETHYLENE- COMPONENTS.**

**5240**

'Yildiz Polietilen Electrofusion and Spigot Fittings'. Black coloured, injection moulded HDPE Electrofusion and Spigot fittings. For use with water up to 60°C.

**APPROVAL NUMBER: 250255032**

**APPROVAL HOLDER: YILDIZ POLIETILEN IMALAT ITH. IHR.SAN.TIC.LTD.STI.**

The Scheme reserves the right to review approval.

Approval 250255032 is valid between February 2025 and February 2030

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wrasapprovals.co.uk/approvals-directory/](http://www.wrasapprovals.co.uk/approvals-directory/)

Yours Faithfully

**Ian Hughes**  
**WRAS Approvals Manager**